

ISO 14644-1:2015					
Date: 2021-06-28 10:22:21					
Targeted Class Level: 4					
Created By: Administrator					
Created On: 2021-06-28 10:01:14					
Operator Name: Joe Krispin					
2021-06-28 10:01:14 to 2021-06-28 10:08:25					
Particle Counter(s) Used					
SOLAIR 3100 (02) (Serial #091204015)					
Cleanroom Information					
Floor Area: 1.000 m ²					
Air Flow: Unidirectional					
State: Operational					
Classification: Pass					
0.5 micron					
Location	Samples	Min Volume (L)	Sample Average (counts)	Average p/m ³	Pass/Fail
Location 001	1	28.3	0.0	0.0	Pass
Location 002	1	28.3	0.0	0.0	Pass
Location 003	1	28.3	0.0	0.0	Pass
Location 004	1	28.3	0.0	0.0	Pass
Location 005	1	28.3	0.0	0.0	Pass
Location 006	1	28.3	0.0	0.0	Pass
				Min Sample Volume Limit (L)	5.682
				ISO Class 5 Limit	3520.0
				Classification	Pass

ISO 14644-1:2015					
Date: 2021-06-28 10:20:10					
Targeted Class Level: 5					
Created By: Administrator					
Created On: 2021-06-28 10:01:14					
Operator Name: Joe Krispin					
2021-06-28 10:01:14 to 2021-06-28 10:08:25					
Particle Counter(s) Used					
SOLAIR 3100 (02) (Serial #091204015)					
Cleanroom Information					
Floor Area: 1.000 m ²					
Air Flow: Unidirectional					
State: Operational					
Classification: Pass					
0.5 micron					
Location	Samples	Min Volume (L)	Sample Average (counts)	Average p/m ³	Pass/Fail
Location 001	1	28.3	0.0	0.0	Pass
Location 002	1	28.3	0.0	0.0	Pass
Location 003	1	28.3	0.0	0.0	Pass
Location 004	1	28.3	0.0	0.0	Pass
Location 005	1	28.3	0.0	0.0	Pass
Location 006	1	28.3	0.0	0.0	Pass
				Min Sample Volume Limit (L)	5.682
				ISO Class 5 Limit	3520.0
				Classification	Pass